

# Water Testing Results - Lighthouse Charter School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Bunkerhill Elementary		6/16/2016	ND

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

Lab Sheets reporting in mg/L - Convert mg/L to ppb by Multiplying by 1,000



Delivering more than just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

# Analytical Report

Date Reported 6/24/2016

WO#: 1606884  
CLIENT: McCowan Clinical Laboratory, Inc.  
Project: Coos Bay School District #9  
PWS Number:  
Sample Source:

Received Date: 6/17/2016 11:35:00 AM  
Sampler Name Mark Crocker  
Matrix: Drinking Water  
Sample Type:

Lab ID: 1606884-001 Client Sample ID Eastside School -- Collection Date: 6/16/2016 7:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Lab ID: 1606884-002 Client Sample ID Bunkerhill -- Collection Date: 6/16/2016 6:50:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Lab ID: 1606884-003 Client Sample ID Millicoma -- Collection Date: 6/16/2016 7:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Lab ID: 1606884-004 Client Sample ID MHS Pirate Hall -- Collection Date: 6/16/2016 7:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Lab ID: 1606884-005 Client Sample ID MHS East Gym -- Collection Date: 6/17/2016 7:36:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00269	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Lab ID: 1606884-006 Client Sample ID MHS Harding School -- Collection Date: 6/17/2016 7:19:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	6/22/2016 9:28:00 PM	KG

Qualifiers:

- \* Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit